



Figure 2: CMDHD Nitrate Testing Summary

CMDHD has conducted water well sampling of residential water wells in the area. The water samples were analyzed for nitrates as indicators of possible septic tank influence on the groundwater supply well. The sampling consisted of 122 wells with 100% of the sample containing detectable levels of nitrates. The highest detection being 23 mg/l (ppm), over twice the maximum contaminant level due to health concerns of 10 ppm.